

Data sheet Micro plate heat exchanger (MPHE): XGM032

Description



Micro Plate Heat Exchangers - a revolutionary technology from Danfoss. Characterized by their unique plate pattern, MPHEs enable heat to be transferred more efficient than any previous model of heat exchangers.

Benefits:

- Energy and cost savings
- Better heat transfer
- Lower pressure loss
- More flexible design
- Longer life time

more on: MPHE.danfoss.com

XGM032 is gasketed plate heat exchanger, designed and configured for District Heating and other Heating applications.


Heat exchanger XGM032 will be available in plate corrugation H, M and L. It will be available in 1-pass version (with 4 connections) and 2-pass version (with 6 connections). Heat exchanger can be dimensioned in Danfoss calculation software "Hexact" which can be downloaded from hexact. danfoss.com.

Approvals:

- Pressure Equipment Directive (PED) 97/23/EC
- GOST/Russia

Ordering

XGM 032 H - 1 - 10



1-pass gasketed heat exchangers type XGM032 (PN 16)

Picture	No. of plates	Connection	XGM032L	XGM032M	XGM032H
	(n)		Code No.		
	20		004H7096	004H7087	004H7078
	30	Thread G 1¼	004H7097	004H7088	004H7079
	40		004H7098	004H7089	004H7080
	50		004H7099	004H7090	004H7081
	60		004H7100	004H7091	004H7082
	70		004H7101	004H7092	004H7083
	80		004H7102	004H7093	004H7084
	90		004H7103	004H7094	004H7085
	100		004H7104	004H7095	004H7086

Note: Brackets has to be ordered separately.

Danfoss

Data sheet

Micro Plate Heat Exchanger (MPHE) XGM032

Ordering - continuous

Accessories - Insulations

Type coverage (plate nos)	Code No.
20-40	004H7117
41-70	004H7118
71-100	004H7119

Accessories - Bracket

Туре	Code No.
Brackets	004H7222

Accessories - EPDM Gasket

Туре	Code No.
Gasket for XGM032, I-pack 10 pcs	004H7128
Gasket for XGM032, I-pack 250 pcs	004H7129

Accessories for gasketed heat exchanger type XGM

Туре	Code No.
Plates for XGM032H PN 16/25, I-pack 10 pcs	004H7186
Plates for XGM032M PN 16/25, I-pack 10 pcs	004H7187
Plates for XGM032L PN 16/25, I-pack 10 pcs	004H7188
Plates for XGM032H PN 16/25, I-pack 250 pcs	004H7189
Plates for XGM032M PN 16/25, I-pack 250 pcs	004H7190
Plates for XGM032L PN 16/25, I-pack 250 pcs	004H7191
XGM032H: spec. plates 1-pass versions, including gaskets. PN 16/25	004H7204
XGM032M: spec. plates 1-pass versions, including gaskets. PN 16/25	004H7205
XGM032L: spec. plates 1-pass versions, including gaskets. PN 16/25	004H7206
XGM032H: spec. plates 2-pass version, including gaskets PN 16/25	004H7219
XGM032M: spec. plates 2-pass version, including gaskets PN 16/25	004H7220
XGM032L: spec. plates 2-pass version, including gaskets PN 16/25	004H7221

Tailpieces for gasketed heat exchanger type XG

Picture	Description	Connection	Code No. ¹⁾
□[] <u>]</u> □	Solder tailpieces	G 1¼ A/22 mm, 28 mm	004B1358
	Weld-on tailpieces		003H6910
	Weld-on talipleces	G 1¼ A/DN 32	004B1343

¹⁾ One set contains 2 tailpieces with union nuts and gaskets

Technical data

Max. working pressure PN (bar)		16 & 25		
Max. operating temperature		150		
°C		-10		
Flow medium		Circulation water / glycolic water up to 50 %		
Volume / Channel		0,097		
Primary side volume:	Ltr	(n/2) -1 x volume/channel		
econdary side volume:		(n/2) x volume/channel		
Connection type		Cylindrical external thread acc. to DIN ISO 228/1		
Connection size		G 1¼		
Plate material		Stainless steel, mat. no. EN 1.4404		
Plate thickness mm		0,3		
Gasket type		Glue free		
Gasket material, rubber		EPDM		

¹⁾ At flow temp. below 2 °C glycolic water must be used

Insulation properties

Туре			Aluminium stucco and mineral wool
Heat conduct	ivity, λ	W/mK	0,042
Max temperature	Permanent	°C	150
	Short term peak		180
Wall thickness		mm	40

Note:

For more details about insulation please contact your Danfoss sales representative.


Data sheet

Sizing

Mounting

Micro Plate Heat Exchanger (MPHE) XGM032

Design and function



XGM032 will be available as standard and tailor made unit. It can be calculated in latest version of Danfoss calculation software "Hexact" ver. 2.1.3 which can be downloaded from

The heat exchanger must be mounted in vertical

exchanger if necessary, always according to local regulations. It is recommended that all pipes

connected to the heat exchanger are equipped

with shut-off valves for maintenance purposes.

The pipes to be connected must be mounted so

that the strain caused by the thermal expansion,

for instance, does not harm the heat exchanger.

position. Prepare the foundation for the heat

hexact.danfoss.com.

The heat exchangers are made of shape-pressed heat plates between which the flow channels are created. Gaskets between the plates separate the flow channels from each other so that the flows do not mix. The heavy turbulence and counter-flow principle enables efficient heat transfer. The task of the heat exchanger is to transfer heat from the primary to secondary flow through a heat transfer plate thus preventing the flows from mixing with each other. The plate heat exchanger with gaskets can be opened for cleaning and for replacement of plates and gaskets. A steeples output adjustment can be carried out by changing the number of plates.

The choice of heat exchanger is determined by the desired heat output, required temperatures and the permitted pressure losses.

C

ant

DEN-SMT/SI

The pipes must be equipped with brackets to prevent any torsional stress concentration at the heat exchanger's pipe connections.


It is recommended that the heat exchanger is equipped with insulation.

A safety valve must be installed between the heat exchanger and the shut-off valves on the secondary side of the heat exchanger. If the safety valve is not installed, thermal expansion of fluid might destroy the heat exchanger when the shut-off valves are closed.

Danfoss

Data sheet

Dimensions¹⁾



¹⁾ Dimensions for 2-pass and PN25 version can be extract from calculating software "Hexact" in tab "Dimensional data".

Danfoss can accept no responsibility for possible errors in catalogues, brochures and other printed material. Danfoss reserves the right to alter its products without notice. This also applies to products already on order provided that such alterations can be made without subsequential changes being necessary in specifications already agreed. All trademarks in this material are property of the respective companies. Danfoss and the Danfoss logotype are trademarks of Danfoss A/S. All rights reserved.